

EntityName	StationName	SampleDate	Ammonia	BOD	Chemical Oxygen Demand	Conductivity @ 20°C	Conductivity @ 25°C	Flow	Fluoride	Mixed Liquor Suspended Solids	Nitrates NO3-N	Nitrites NO2-N	Ortho-phosphate (PO4-P)	pH	Sulphate	Suspended Solids	Total Nitrogen	Total Oxidised Nitrogen (N)	Total Phosphate
Boyle STP	Effluent	29/01/2009	0.56	0.98	47	550	608	3137	<0.1		3.003	0.04	0.02	7.45		3		3.043	0.046
Boyle STP	Influent	29/01/2009	6.19	53	231			4139			1.351	0.034	0.36	7.43		114		1.385	0.808
Boyle STP	MLSS	29/01/2009								1372				7.23					
Boyle STP	MLSS	29/01/2009								1040				7.22					
Boyle STP	MLSS	29/01/2009								1052				7.19					
Boyle STP	MLSS	29/01/2009								1084				7.23					
Boyle STP	Effluent	17/02/2009	14.2	18	95	740	818	1105	0.1		0.056	0.044	2.69	7.55		45		0.101	3.175
Boyle STP	Influent	17/02/2009	11.65	RNV	342			1584			0.812	0.033	1.221	7.53		98		0.845	RNV
Boyle STP	MLSS	17/02/2009								1645				RNV					
Boyle STP	MLSS	17/02/2009								1670				7.35					
Boyle STP	MLSS	17/02/2009								2495				7.26					
Boyle STP	MLSS	17/02/2009								1790				7.37					
Boyle STP	Effluent	25/03/2009	0.04	2.25	43	494	546	NT	0.12		5.672	0.016	0.205	7.65	27.71	5		5.688	0.285
Boyle STP	Influent	25/03/2009	18.74	179	549			NT			RNV	0.001	2.02	7.55		339		<0.007	4.02
Boyle STP	MLSS	25/03/2009								5156				7.16					
Boyle STP	MLSS	25/03/2009								5040				7.16					
Boyle STP	MLSS	25/03/2009								5036				7.15					
Boyle STP	MLSS	25/03/2009								4620				7.28					
Boyle STP	Effluent	21/04/2009	0.052	1.54	12		819	2218	0.069		6.409	0.009	0.148	7.57	28.06	6		6.418	0.364
Boyle STP	Influent	21/04/2009	16.49	612	1359			1654			<0.006	0.122	2.79	7.42		957		0.098	17.2
Boyle STP	MLSS	21/04/2009								4180				7.17					
Boyle STP	MLSS	21/04/2009								4028				7.04					
Boyle STP	MLSS	21/04/2009								3880				7.24					
Boyle STP	MLSS	21/04/2009								3988				7.05					
Boyle STP	Effluent	19/05/2009	2.36	1.36	<6		570	5088	0.107		0.783	0.029	0.316	7.68	19.66	0		0.812	0.549
Boyle STP	Influent	19/05/2009	6.09	104	251			3323			0.696	0.041	0.19	7.56		167		0.737	3.91
Boyle STP	MLSS	19/05/2009								3392				6.88					
Boyle STP	MLSS	19/05/2009								3552				7.03					
Boyle STP	MLSS	19/05/2009								3772				7					
Boyle STP	MLSS	19/05/2009								3504				6.89					
Boyle STP	Effluent	16/06/2009	0.353	3.63	10.5		818	937.4	0.173		8.227	0.036	1.71	7.87	27.75	7.5		8.263	1.96
Boyle STP	Influent	16/06/2009	17.62	392	749			980.5			0.056	0.025	5.57	7.27		1031		0.081	27.9
Boyle STP	MLSS	16/06/2009								5204				7.05					
Boyle STP	MLSS	16/06/2009								4004				7.11					
Boyle STP	MLSS	16/06/2009								4380				7.08					
Boyle STP	MLSS	16/06/2009								4276				7.12					
Boyle STP	Effluent	16/07/2009	0.041	6.46	38.7		613	2133	0.226		5.099	<0.004	0.45	7.74	29.61	9		5.099	0.701
Boyle STP	Influent	16/07/2009	3.91	356	546			2569			1.308	0.019	1.3	7.34		622		1.327	13.5
Boyle STP	MLSS	16/07/2009								2312				7.27					
Boyle STP	MLSS	16/07/2009								2432				7.28					
Boyle STP	MLSS	16/07/2009								3264				7.26					
Boyle STP	MLSS	16/07/2009								2600				7.37					
Boyle STP	Effluent	25/08/2009	0.016	1.17	47		613		0.119		4.575	<0.004	0.28	7.7	27.63	4		4.575	0.425
Boyle STP	Influent	25/08/2009	2.56	138.15	391						1.779	0.044	0.02	7.35		228		1.823	4.11
Boyle STP	MLSS	25/08/2009								2108				7.38					
Boyle STP	MLSS	25/08/2009								2092				7.25					
Boyle STP	MLSS	25/08/2009								1972				7.37					
Boyle STP	MLSS	25/08/2009								2076				7.41					
Boyle STP	Effluent	30/09/2009	0.021	3.5	81.7		868		0.126		13.849	0.006	1.45	7.53	25.53	231		13.855	2.96
Boyle STP	Influent	30/09/2009	15.62	127	148						0.394	0.08	2.6	7.55		17		0.474	4.27
Boyle STP	MLSS	30/09/2009								412				7.33					
Boyle STP	MLSS	30/09/2009								1620				7.14					

Boyle STP	MLSS	30/09/2009							1516			7.2						
Boyle STP	MLSS	30/09/2009							1708			7.3						
Boyle STP	Effluent	22/10/2009	0.018	2.29	22.7		779	579	0.967		18.423	0.004	1.74	7.56	29.32	18.5	18.427	2.31
Boyle STP	Influent	22/10/2009	6.86	153	502			886			4.618	0.322	1.67	7.66		380	4.94	2.02
Boyle STP	MLSS	22/10/2009								2096				7.44				
Boyle STP	MLSS	22/10/2009								2128				7.26				
Boyle STP	MLSS	22/10/2009								1712				7.19				
Boyle STP	MLSS	22/10/2009								2376				7.2				
Boyle STP	Effluent	16/12/2009	3.09	1.86	20.7			952.2	0.119		0.803	0.045	0.014	7.78	79.33	9	0.848	0.826
Boyle STP	Influent	16/12/2009	11.46	554	1780			1527.1			0.041	0.035	1.95	7.08		748	0.076	12.2
Boyle STP	MLSS	16/12/2009								1448				7.52				
Boyle STP	MLSS	16/12/2009								1416				7.37				
Boyle STP	MLSS	16/12/2009								1484				7.35				
Boyle STP	MLSS	16/12/2009								980				7.37				
Boyle STP	Effluent	21/12/2009	0.079	4.73	2.1		NT		0.103		11.122	0.134	0.8	7.89	19.27	16.5	11.256	1.49
Boyle STP	Effluent	19/01/2010	0.01	1.24	51			1314.5	0.129		6.592	<0.004	0.344	7.5	21.2	18.5	6.592	0.484
Boyle STP	Influent	19/01/2010	4.92	101	303			1451.9			0.887	0.098	0.33	7.52		133	0.985	2.74
Boyle STP	MLSS	19/01/2010								2328				7.32				
Boyle STP	MLSS	19/01/2010								2496				7.12				
Boyle STP	MLSS	19/01/2010								2296				7.15				
Boyle STP	MLSS	19/01/2010								2544				7.25				
Boyle STP	Effluent	09/02/2010	0.013	2	15		767						0.99	8.61		7	12.5	1.15
Boyle STP	Influent	09/02/2010	20.82	120	269								1.84	8.38		113		3.4
Boyle STP	MLSS	09/02/2010								2084				8.29				
Boyle STP	MLSS	09/02/2010								1844				7.74				
Boyle STP	MLSS	09/02/2010								1496				7.22				
Boyle STP	MLSS	09/02/2010								1752				7.62				
Boyle STP	Effluent	24/03/2010	0.035	4	29.4		767						0.76	7.56		<7		1.05
Boyle STP	Influent	24/03/2010	7.6	71	172								0.49	7.47		71		1.63
Boyle STP	MLSS	24/03/2010								1980				7.76				
Boyle STP	MLSS	24/03/2010								2092				7.7				
Boyle STP	MLSS	24/03/2010								2112				7.8				
Boyle STP	MLSS	24/03/2010								2304				7.78				