

EntityName	StationName	SampleLabCode	SampleDate	Ammonia	BOD	Chemical Oxygen Demand	Conductivity @ 20°C	Conductivity @ 25°C	Fluoride	Mixed Liquor Suspended Solids	Nitrates NO3-N	Nitrites NO2-N	Ortho-phosphate (PO4-P)	pH	Sulphate	Suspended Solids	Temperature	Total Oxidised Nitrogen (N)	Total Phosphate
Strokestown STP	Effluent	094400040	20/01/2009	0.018	2.03	37	695	768			6.616	0.016	0.55	7.55		5		6.632	0.786
Strokestown STP	Influent	094400038	20/01/2009	4.106	48	87					0.308	0.116	0.43	7.56		83		0.424	0.458
Strokestown STP	MLSS	094400039	20/01/2009							1900				7.48					
Strokestown STP	Effluent	094400276	24/02/2009	0.034	1.89	23	764	845	0.36		14.786	0.063	0.854	7.54	25.83	7	11.3	14.849	0.894
Strokestown STP	Influent	094400274	24/02/2009	13.68	82	216					<0.006	0.007	1.227	7.58		69		<0.007	1.84
Strokestown STP	MLSS	094400275	24/02/2009							12900				7.35					
Strokestown STP	Effluent	094400464	25/03/2009	0.303	3.33	71	836	924	0.547		12.154	0.266	0.58	7.49	24.8	4	NT	12.42	0.902
Strokestown STP	Influent	094400462	25/03/2009	12.185	90	179					0.389	0.079	0.9	7.94		64		0.468	1.7
Strokestown STP	MLSS	094400463	25/03/2009							3456				7.46					
Strokestown STP	Effluent	094400584	15/04/2009	0.072	1.38	<6		745	0.717		9.453	0.021	0.519	7.74	26.91	1	10	9.474	0.554
Strokestown STP	Influent	094400582	15/04/2009	11.46	55	62					0.388	0.072	0.944	7.78		57		0.46	1.83
Strokestown STP	MLSS	094400583	15/04/2009							2780				7.62					
Strokestown STP	Effluent	094400757	07/05/2009	0.044	1.74	<6		676	0.5		10.503	0.052	0.22	7.66	18.63	4		10.555	0.365
Strokestown STP	Influent	094400755	07/05/2009	13.61	54	168					0.047	0.257	0.98	7.78		49		0.304	1.92
Strokestown STP	MLSS	094400756	07/05/2009							1968				7.61					
Strokestown STP	Effluent	094400980	04/06/2009	0.18	1.09	26		861	0.521		13.579	0.316	0.15	7.6	29.52	4		13.895	0.252
Strokestown STP	Influent	094400978	04/06/2009	34.95	124	229					<0.032	0.012	2.26	7.91		129		<0.036	3.99
Strokestown STP	MLSS	094400979	04/06/2009							2912				7.39					
Strokestown STP	Effluent	094401204	08/07/2009	0.064	1.89	32		666	0.571		5.211	0.092	0.2	7.58	29.22	5		5.303	0.361
Strokestown STP	Influent	094401202	08/07/2009	19.92	87	235					0.046	0.097	1.59	7.66		91		0.143	3.62
Strokestown STP	MLSS	094401203	08/07/2009							3584				7.52					
Strokestown STP	Effluent	094401502	20/08/2009	<0.01	RNV	597		479			3.227	<0.004	0.36	7.48	20.03	524		3.227	AR
Strokestown STP	Influent	094401500	20/08/2009	4.97	6.05	36					1.347	0.1	0.44	7.56		13.33		1.447	0.71
Strokestown STP	MLSS	094401501	20/08/2009							1252				7.37					
Strokestown STP	Effluent	094401679	10/09/2009	0.034	1.4	35.4		712	0.234		5.053	0.02	0.155	7.74	25	7.5		5.073	0.354
Strokestown STP	Influent	094401677	10/09/2009	25.65	71.5	61					0.032	<0.004	2.09	7.94		93		<0.036	2.88
Strokestown STP	MLSS	094401678	10/09/2009							2644				7.53					
Strokestown STP	Effluent	094402021	22/10/2009	0.351	2.66	9.7		633	0.237		8.204	0.465	0.48	7.56	26.4	15.5		8.669	1.08
Strokestown STP	Influent	094402019	22/10/2009	10.49	99.9	349					<0.032	0.006	0.98	7.57		163		<0.036	2.76
Strokestown STP	MLSS	094402020	22/10/2009							900				7.61					
Strokestown STP	Effluent	094402175	17/11/2009	0.012	2.23	26	488	572	0.221		3.967	0.064	0.64	7.66	15.57	6		4.031	0.969
Strokestown STP	Influent	094402173	17/11/2009	2.31	42.9	134					1.058	0.055	0.17	7.65		30.8		1.113	0.753
Strokestown STP	MLSS	094402174	17/11/2009							3288				7.38					
Strokestown STP	Effluent	094402381	10/12/2009	0.026	1.91	22.5		0.375			7.323	0.029	0.058	7.58	20.99	4		7.352	0.119
Strokestown STP	Influent	094402379	10/12/2009	15.32	101	188					0.536	0.069	1.36	7.65		81		0.605	2.53
Strokestown STP	MLSS	094402380	10/12/2009							3424				7.5					
Strokestown STP	Effluent	104400014	12/01/2010	0.028	1.66	27		NT	0.255		14.043	0.039	0.8	7.48	26.66	6.5		14.082	1.05
Strokestown STP	Influent	104400012	12/01/2010	16.09	62	145					0.711	0.091	1.07	7.87		55		0.802	2.79
Strokestown STP	MLSS	104400013	12/01/2010							4876				7.46					
Strokestown STP	Effluent	104400173	03/02/2010	<0.01	9	32.6		768			NT	NT	0.25	7.85		39		NT	0.797
Strokestown STP	Influent	104400172	03/02/2010	4.71	137	377					NT	NT	0.36	7.75		107		NT	1.34
Strokestown STP	MLSS	104400174	03/02/2010							3093				7.69					
Strokestown STP	Effluent	104400398	03/03/2010	0.049	RNV	60		861					NT	7.88		37			2.61
Strokestown STP	Influent	104400397	03/03/2010	16.4	RNV	227							NT	7.97		115			2.8
Strokestown STP	MLSS	104400399	03/03/2010							3372				7.73					

Exceedances in Red