

ROSCOMMON COUNTY COUNCIL

PLANNING AND DEVELOPMENT ACT 2000 (as amended)

SECTION 5 - DECLARATION ON DEVELOPMENT AND EXEMPTED DEVELOPMENT

CHIEF EXECUTIVE'S ORDER

Order No:

PL/1044/26.

Reference Number:

DED1055

Name of Applicant:

Sean Wallace

Agent:

Jack Reilly, Waldron & Associates

WHEREAS a question has arisen as to whether the construction of a class 6 cow shed with an accompanying class 6A effluent storage tank at Ballyhubert, Scramoge, Co. Roscommon, F42 HX84, is or is not development and is or is not exempted development:

AND WHEREAS Roscommon County Council, in considering this application, had regard particularly to:

- (a) Sections 2, 3, 4 and 5 of the Planning and Development Act, 2000, as amended.
- (b) Articles 6 and 9 of the Planning and Development Regulations, 2001, as amended.
- (c) Class 6 and Class 6A Part 3 Schedule 2 Article 6 of the Planning and Development Regulations 2001, as amended.
- (d) The record forwarded to Roscommon County Council in accordance with subsection (6)(c) of Section 5 of the Planning and Development Acts 2000 as amended.
- (e) The planning history of the site.

AND WHEREAS Roscommon County Council has concluded that:

- The works outlined above are development.
- The proposed development individually and in combination with other plans or projects would not be likely to have a significant effect on any European site and that the requirement for AA or EIAR does not apply with respect to the current case.
- The proposed development does not exceed the conditions and limitations of Class 6 and Class 6A Part 3 Schedule 2 Article 6 of the Planning and Development Regulations, 2001, as amended and is therefore, an exempted development.

NOW THEREFORE:

By virtue of the powers vested in me by the Local Government Acts 1925 – 2024 and Section 5(2)(a) of the Planning and Development Act 2000 (as amended) and having considered the various submissions and reports in connection with the application described above, it is hereby declared that the said development for the construction of a class 6 cow shed with an accompanying class 6A effluent storage tank at Ballyhubert, Scramoge, Co. Roscommon, F42 HX84, is development that is **exempted development** as defined within the Planning and Development Act 2000 (as amended) and associated Regulations.

Signed on behalf of the Council:

Signed: 

Alan O'Connell,
Senior Executive Planner,
Planning.

Date: 27/06, 2026

Gemma Cunningham

From: Gemma Cunningham
Sent: Wednesday 2 September 2026 15:45
To: jackreilly@waldrons.ie
Cc: [REDACTED]
Subject: DED1055 Notification of Decision
Attachments: ded1055 notification.pdf

A Chara,

Please find attached correspondence for your attention regarding DED1055.

Kind Regards,

Gemma Cunningham | Clerical Officer

Áras an Chontae, Roscommon, Co. Roscommon. F42 VR98

☎ (090) 664 7420 ✉ GCunningham@roscommoncoco.ie

🌐 www.roscommoncoco.ie



Comhairle Contae
Ros Comáin
Roscommon
County Council



Please note that I may be sending this email outside your working hours and I do not expect a response or action outside your own working hours

ROSCOMMON COUNTY COUNCIL
PLANNING AND DEVELOPMENT ACT, 2000 (as amended)
SECTION 5 - DECLARATION ON DEVELOPMENT AND EXEMPTED DEVELOPMENT
NOTIFICATION OF DETERMINATION

REGISTERED POST

Sean Wallace,
Ballyhubert,
Scramoge,
Co. Roscommon,
F42 HX84.

Reference Number: DED1055
Application Received: 30th June 2026
Name of Applicant: Sean Wallace
Agent: Jack Reilly, Waldron & Associates

WHEREAS a question has arisen as to whether the construction of a class 6 cow shed with an accompanying class 6A effluent storage tank at Ballyhubert, Scramoge, Co. Roscommon, F42 HX84, is or is not development and is or is not exempted development.

AND WHEREAS Roscommon County Council, in considering this application, had regard particularly to:

- (a) Sections 2, 3, 4 and 5 of the Planning and Development Act, 2000, as amended.
- (b) Articles 6 and 9 of the Planning and Development Regulations, 2001, as amended.
- (c) Class 6 and Class 6A Part 3 Schedule 2 Article 6 of the Planning and Development Regulations 2001, as amended.
- (d) The record forwarded to Roscommon County Council in accordance with subsection (6)(c) of Section 5 of the Planning and Development Acts 2000 as amended.
- (e) The planning history of the site.


AND WHEREAS Roscommon County Council has concluded that:

- The works outlined above are development.
- The proposed development individually and in combination with other plans or projects would not be likely to have a significant effect on any European site and that the requirement for AA or EIAR does not apply with respect to the current case.
- The proposed development does not exceed the conditions and limitations of Class 6 and Class 6A Part 3 Schedule 2 Article 6 of the Planning and Development Regulations, 2001, as amended and is therefore, an exempt development.

NOW THEREFORE:

By virtue of the powers vested in me by the Local Government Acts 1925 – 2024 and Section 5(2)(a) of the Planning and Development Act 2000 (as amended) and having considered the various submissions and reports in connection with the application described above, it is hereby declared that the said development for the construction of a class 6 cow shed with an accompanying class 6A effluent storage tank at Ballyhubert, Scramoge, Co. Roscommon, F42 HX84, is development that is **exempted development** as defined within the Planning and Development Act 2000 (as amended) and associated Regulations.

Signed on behalf of the Council:


Mervyn Walsh,
Administrative Officer,
Planning.

Date: 28/08/2026

ADVICE NOTE

Any person issued with a Declaration under Section 5 of the Planning and Development Act, 2000 (as amended) may, on payment to An Coimisiún Pleanála of the prescribed fee, refer a Declaration for review within 4 weeks of the date of the issuing of the Declaration.

ADVICE NOTE

This Declaration is based on the relevant Planning and Development Act 2000 (as amended) and the Planning and Development Regulations 2001 (as amended) at the date of issue. In the event that the Planning and Development Act 2000 (as amended) or the Planning and Development Regulations 2001 (as amended) change prior to the works being carried out this Declaration may no longer apply.

**Planner's Report on application under
Section 5 of the Planning and Development Act 2000 (as amended)**

Reference Number:	DED 1055
Re:	Application for a Declaration under Section 5 of the Planning & Development Act, 2000, as amended, regarding Exempted Development as to whether a proposed class 6 cow shed with an accompanying class 6A effluent storage tank is or is not development and is or is not exempted development.
Name of Applicant:	Sean Wallace
Location of Development:	Ballyhubert, Scramoge, Co. Roscommon, F42 HX84
Site Visit:	17 th July 2026

WHEREAS a question has arisen as to whether the construction of a class 6 cow shed with an accompanying class 6A effluent storage tank **at the above address is or is not development and is or is not exempted development.**

I have considered this question, and I have had regard particularly to –

- (a) Sections 2, 3, 4 and 5 of the Planning and Development Act, 2000, as amended.
- (b) Articles 6 and 9 of the Planning and Development Regulations 2001, as amended.
- (c) Class 6 and 6A Part 3 Schedule 2 Article 6 of the Planning and Development Regulations 2001, as amended.
- (d) The record forwarded to Roscommon County Council in accordance with subsection (6)(c) of Section 5 of the Planning and Development Acts 2000 as amended.
- (e) The planning history of the site.


Site Location & Development Description

The site consists of an existing farmyard with agricultural structures/sheds present and an existing west facing dwelling. The subject site is situated in the townland of Ballyhubert c. 5.2km southeast of Strokestown. The existing farmyard is accessed off the L-6083 Local Primary Road. The proposed development consists of the construction of a class 6 cow shed with an accompanying class 6A effluent storage tank.

Archaeological and Cultural Heritage

No RMP recorded in the likely zone of influence of the proposed development. No Protected structures or structures listed in the National Inventory of Architectural Heritage in the likely zone of influence of the proposed development.

Appropriate Assessment



The closest European site to the proposed development is Annaghmore Lough (Roscommon) SAC (Site Code 001626) located c. 7.7km northwest of the subject site and Lough Forbes Complex SAC (Site Code 001818) located c. 8.5km east of the subject.

Having regard to the separation distance between the site and the closest Natura 2000 site and the nature of the proposal, there is no real likelihood of significant effects on the conservation objectives of these or other European sites arising from the proposed development. The need for further Appropriate Assessment can, therefore, be excluded.

Planning History

As per Roscommon County Councils Planning Registry, there is no recent planning history attached to the subject site.

Relevant statutory provisions

Planning and Development Acts 2000 (as amended)

Section 2. –(1)

“works” includes any act or operation of construction, excavation, demolition, extension, alteration, repair or renewal and, in relation to a protected structure or proposed protected structure, includes any act or operation involving the application or removal of plaster, paint,

wallpaper, tiles or other material to or from the surfaces of the interior or exterior of a structure.

Section 3. –(1)

In this Act, “development” means, except where the context otherwise requires, the carrying out of any works on, in, over or under land or the making of any material change in the use of any structures or other land.

Section 4 (2) of the Planning and Development Act provides that the Minister, by regulations, provide for any class of development to be exempted development. The principal regulations made under this provision are the Planning and Development Regulations.

Planning and Development Regulations, 2001 as amended

Article 6 (1)

Subject to article 9, development of a class specified in column 1 of Part 3 of Schedule 2 shall be exempted development for the purposes of the Act, provided that such development complies with the conditions and limitations specified in column 2 of the said Part 3 opposite the mention of that class in the said column 1.

Article 9 (1) applies;

Development to which article 6 relates shall not be exempted development for the purposes of the Act.

viiB) comprise development in relation to which a planning authority or an Bord Pleanála is the competent authority in relation to appropriate assessment and the development would require an appropriate assessment because it would be likely to have a significant effect on the integrity of a European site.

Class 6 Part 3 Schedule 2 Article 6

Development Description	Conditions and Limitations
Agricultural Structures CLASS 6 Works consisting of the provision of a roofed structure for housing of cattle, sheep, donkeys, horses, deer or rabbits, having a gross floor space not exceeding 300 square metres (whether or not by extension of an existing structure), and any ancillary provision of effluent storage.	1. No such structure shall be used for any purpose other than the purpose of agriculture. 2. The gross floor space of such structure together with any other such structures situated within the same farmyard complex or within 100 metres of that complex shall not exceed 450 square metres gross floor space in aggregate. 3. Effluent storage facilities adequate to serve the structure having regard to its size, use

	and location, shall be constructed in accordance with Department of Agriculture, Food and Rural Development and Department of the Environment and Local Government requirements and shall have regard to the need to avoid water pollution. 4. No such structure shall be situated, and no effluent from such structure shall be stored, within 10 metres of any public road. 5. No such structure within a 100m metres of any public road shall exceed 8 metres in height. 6. No such structure shall be situated, and no effluent from such structure shall be stored, within 100 metres of any house (other than the house of the person providing the structure) or other residential building or school, hospital, church or building used for public assembly, save with the consent in writing of the owner and, as may be appropriate, the occupier or person in charge thereof. 7. No such structure shall be constructed within a flood zone identified in statutory land use plans as Flood Zone A or Flood Zone B or where the probability of flooding is moderate to high or erosion control zone. 8. No such structure shall be within 60 metres of a public or private water source. 9. No such structure shall be situated, at the closest point, less than 50 metres from a water course or water body in the case of new farmyards, and not less than 10 metres in the case of extensions/modifications to an existing facility. 10. No unpainted metal sheeting shall be used for roofing or on the external finish of the structure. 11. The use of this Class of exemption requires a declaration from the relevant Planning Authority under section 5 of the Principal
--	--

CLASS 6A Works consisting of the provision of a structure for the storage of slurry, effluent or soiled water collected from agricultural buildings, agricultural farmyards and any ancillary provision to aid in the handling of the slurry, effluent or soiled water.	Act, declaring the exemption is applicable prior to commencement of construction. 12. Ancillary provision shall include as appropriate the installation of any signage, fencing or other safety infrastructure as recommended by the Health and Safety Authority regarding Slurry Safety. 1. No such structure shall be used for any purpose other than the purpose of agriculture. 2. The maximum storage capacity of any such storage facility shall not exceed 1000 cubic metres. 3. The aggregate capacity of tanks, situated within the same farmyard complex, shall not exceed 1,500 cubic metres. 4. The structure having regard to its size, use and location shall be constructed in accordance with Department of Agriculture, Food and the Marine and Department of Housing, Local Government and Heritage requirements and shall have regard to the need to avoid water pollution. The structure shall not be an earth lined Slurry/Effluent Store. 5. No such structure shall be situated, and no effluent from such structure shall be stored, within 10 metres of any public road. 6. No such structure within 100 metres of any public road shall exceed 8 metres in height. 7. No such structure shall be situated, and no effluent from such structure shall be stored, within 100 metres of any house (other than the house of the person providing the structure) or other residential building or school, hospital, church or building used for public assembly, save with the consent in writing of the owner and, as may be
--	---

	appropriate, the occupier or person in charge thereof. 8. No such structure shall be constructed within a flood zone identified in statutory land use plans as Flood Zone A or Flood Zone B or where the probability of flooding is moderate to high or erosion control zone. 9. No such structure shall be within 60 metres of a public or private water source. 10. No such structure shall be situated, at the closest point, less than 50 metres from a water course or water body in the case of new farmyards, and not less than 10m in the case of extensions/modifications to an existing facility. 11. All such tanks shall be constructed in accordance with the relevant specification published by the Department of Agriculture, Food and the Marine in force at the time of construction of the tank. 12. No unpainted metal sheeting shall be used for roofing or on the external finish of the structure. 13. The use of this Class of exemption requires a declaration from the relevant Planning authority under section 5 of the Principal Act, declaring the exemption is applicable prior to commencement of construction. 14. Ancillary provision shall include as appropriate the installation of any signage, fencing or other safety infrastructure as recommended by the Health and Safety Authority regarding Slurry Safety.
--	---

Environmental Considerations

With regard to Article 9 (1)(a) of the Planning and Development Regulations 2001 (as amended), it is reasonable to conclude, on the basis of the information available, that the proposed development individually and in combination with other plans or projects would not be likely to have a significant effect on any European site and that the need for AA does not apply with respect to the current case.

I am satisfied that an Environmental Impact Statement or Appropriate Assessment are not required. It should be noted that any development for which Environmental Impact Assessment or Appropriate Assessment is required shall not be exempted development unless specifically exempted in regulations where there is provision in other legislation for the carrying out of EIA or AA. In addition, the restrictions on exemption Article 9 (1)(a) (viiB) exclude development which would otherwise be exempted development under these regulations where an AA is required.

Assessment

In accordance with the Planning and Development Act, 2000, as amended Section 3. (1) development is defined as the following: "In this Act, "development" means, except where the context otherwise requires, the carrying out of any works on, in, over or under land or the making of any material change in the use of any structures or other land". The proposed development is considered to be the carrying out of works. Works are defined in the Act as; "works" includes any act or operation of construction, excavation, demolition, extension, alteration, repair or renewal and, in relation to a protected structure....". It is considered that said works constitute development, as defined in Section 3 of the said Act.

Extent of Works

- The construction of a class 6 cow shed (104.5m²) with an accompanying class 6A effluent storage tank (91.5 m³).

CLASS 6

1. The proposed use for the structure is agriculture.
2. The proposed structure plus other such structures' floor space do not aggregate to more than 450 square meters (322.4sqm).
3. The proposed structure in question is in line with Department requirements, and the applicant shall have regard to the need to avoid water pollution.
4. The proposed structure is situated more than 10 metres from a public road (50m).
5. The proposed structure is less than 8m in height (5.81m).
6. The proposed structure is situated more than 100m from a residential property other than the person providing the structure.
7. The proposed structure is not situated in land use plans as Flood Zone A or Flood Zone B.
8. The proposed structure is greater than 60m from a public or private water source.
9. The proposed structure is greater than 10m from a water course or water body.
10. The proposed sheeting for the structure is corrugated roofing panels and steel.
11. Yes

12. The responsibility lies with the applicant to include as appropriate the installation of signage, fencing or other safety infrastructure as recommended by the Health and Safety Authority regarding Slurry Safety.

CLASS 6A

1. The proposed use for the structure is agriculture.
2. The proposed storage capacity of the proposed storage facility does not exceed 1000m³ (91.5m³).
3. The aggregate of all tanks situated within the same farmyard complex does not exceed 1500m³.
4. The structure is in accordance with Department of Agriculture, Food and the Marine and the Department of Housing, Local Government and Heritage requirements and shall have regard to the need to avoid water pollution.
5. The proposed structure is situated more than 10 metres from a public road (50m).
6. The proposed structure is less than 8 metres in height.
7. The proposed structure is situated greater than 100m from a residential property other than the person providing the structure.
8. The proposed structure is not situated in land use plans as Flood Zone A or Flood Zone B.
9. The proposed structure is greater than 60m from a public or private water source.
10. The proposed structure is greater than 10m from a water course or water body.
11. The proposed structure is in accordance with relevant specification published by the Department of Agriculture, Food and the Marine.
12. The proposed sheeting for the structure is corrugated roofing panels and steel.
13. Yes
14. The responsibility lies with the applicant to include as appropriate the installation of any signage, fencing or other safety infrastructure as recommended by the Health and Safety Authority regarding Slurry Safety.

Recommendation


WHEREAS a question has arisen as to whether the construction of a class 6 cow shed with an accompanying class 6A effluent storage tank at Ballyhubert, Scramoge, Co. Roscommon, F42 HX84, is or is not development and is or is not exempted development, I have considered this question, and I have had regard particularly to –

- (a) Sections 2, 3, 4 and 5 of the Planning and Development Act, 2000, as amended.
- (b) Articles 6 and 9 of the Planning and Development Regulations, 2001, as amended.
- (c) Class 6 and Class 6A Part 3 Schedule 2 Article 6 of the Planning and Development Regulations 2001, as amended.
- (d) The record forwarded to Roscommon County Council in accordance with subsection (6)(c) of Section 5 of the Planning and Development Acts 2000 as amended.
- (e) The planning history of the site.

AND WHEREAS I have concluded that

- The works outlined above are development.
- The proposed development individually and in combination with other plans or projects would not be likely to have a significant effect on any European site and that the requirement for AA or EIAR does not apply with respect to the current case.
- The proposed development does not exceed the conditions and limitations of Class 6 and Class 6A Part 3 Schedule 2 Article 6 of the Planning and Development Regulations, 2001, as amended and is therefore, an exempt development.

AND WHEREAS I have concluded that the construction of a class 6 cow shed with an accompanying class 6A effluent storage tank at Ballyhubert, Scramoge, Co. Roscommon, F42 HX84, is exempted development. I recommend that a declaration to that effect should be issued to the applicant.

Signed: 
Graduate Planner

Date: 25th August 2026


Signed:
Senior Executive Planner

Date: 25th August 2026









MEMORANDUM

To: North Roscommon Area.

From: Mervyn Walsh, Administrative Officer, Planning Department.

Date: 03rd July 2026

Re: Application for a Declaration under Section 5 of the Planning & Development Act 2000 (as amended), regarding Exempted Development.


Development: WHEREAS a question has arisen as to whether a proposed class 6 cow shed with an accompanying class 6A effluent storage tank at Ballyhubert, Scramoge, Co. Roscommon, F42 HX84, is or is not development and is or is not exempted development.

Applicant: Sean Wallace

Planning Ref: DED1055

Attached, please find an application for a Declaration under Section 5 of the Planning & Development Act 2000 (as amended) regarding Exempted Development from **Sean Wallace** for the said development above, **which was received on 30th June 2026.**

Please let me have your recommendation.



Mervyn Walsh,
Administrative Officer,
Planning Department.

Gemma Cunningham

From: Gemma Cunningham
Sent: Tuesday 7 July 2026 12:29
To: 'jackreilly@waldrons.ie'
Cc: [REDACTED]
Subject: DED1055
Attachments: DED1055 Ack letter & Fee Receipt.pdf

A Chara,

Please find attached Acknowledgement letter and Receipt for the Section 5 Declaration of Exempted Development Application Submitted on behalf of Sean Wallace DED1055 is the reference for this application.

Kind Regards,

Gemma

Gemma Cunningham | Clerical Officer

Áras an Chontae, Roscommon, Co. Roscommon. F42 VR98

☎ (090) 664 7420 ✉ GCunningham@roscommoncoco.ie


🌐 www.roscommoncoco.ie



Comhairle Contae
Ros Comáin
Roscommon
County Council



Please note that I may be sending this email outside your working hours and I do not expect a response or action outside your own working hours



Comhairle Contae
Ros Comáin
Roscommon
County Council



Sean Wallace,
Ballyhubert,
Scramoge,
Co. Roscommon.
F42 HX84.

Date: 03rd July 2026
Planning Reference: DED1055

Re: Application for a Declaration under Section 5 of the Planning & Development Act 2000 (as amended), regarding Exempted Development.

Development: WHEREAS a question has arisen as to whether a proposed class 6 cow shed with an accompanying class 6A effluent storage tank at Ballyhubert, Scramoge, Co. Roscommon, F42 HX84, is or is not development and is or is not exempted development.

A Chara,

I wish to acknowledge receipt of your application which was received on the **30th June, 2026**, for a Declaration under Section 5 of the Planning & Development Act 2000 (as amended), regarding Exempted Development along with the appropriate fee in the sum of **€80.00, Receipt No. L01/0/241548 dated 03rd July 2026**, receipt enclosed herewith.

Note: Please note your Planning Reference No. is **DED1055**.
This should be quoted in all correspondence and telephone queries.

Mise le meas,


Mervyn Walsh,
Administrative Officer,
Planning Department.

cc agent via email: Jack Reilly, Waldron & Associates
jackreilly@waldrons.ie

Roscommon County Council
Aras an Chontae
Roscommon
09066 37100

03/07/2028 10:13:03

Receipt No. : L01/0/241548

SEAN WALLACE


EXEMPTED DEVELOPMENT

PLANNING APPLICATION FEES	80.00
GOODS	80.00
VAT Exempt/Non-vatable	
DED 1055	

Total : 80.00 EUR

Tendered :
Credit/Debit Card 80.00
5597

Change : 0.00

Issued By : Louis Carroll
From : Central Cash Office



Comhairle Contae
Ros Comáin
Roscommon
County Council

Áras an Chontae,
Roscommon,
Co. Roscommon.

Phone: (090) 6637100

Email: planning@roscommoncoco.ie



Roscommon County Council


Application for a Declaration under Section 5 of the

Planning & Development Act 2000 (as amended), regarding Exempted Development

Name of Applicant(s)	Sean Wallace
Name of Agent	Jack Reilly
Nature of Proposed Works	Proposed Class 6 Cow Shed with an accompanying Class 6A Effluent Storage Tank.
Location & Address of Subject Property to include, Eircode (where applicable), Townland & O.S No.	Ballyhubert, Scramoge, Co. Roscommon, F42 HX84. OS Map: 2227
Floor Area: a) Existing Structure b) Proposed Structure	Existing Class 6 structures: 322.4m ² Existing Class 6A Volume: 0m ³ b) Proposed Class 6 structure: 104.5m ² Proposed Class 6A Volume: 91.5m ³
Height above ground level:	5.81m
Total area of private open space remaining after completion of this development	N/A
Roofing Material (Slates, Tiles, other) (Specify)	Corrugated roofing pannels

Roscommon County Council

Application for a Declaration under Section 5 of the



Proposed external walling (plaster, stonework, brick or other finish, giving colour)	Steel & Concrete
Is proposed works located at front/rear/side of existing house.	Farm Yard (Right Side of Dwelling)
Has an application been made previously for this site	-
If yes give ref. number (include full details of existing extension, if any)	-
Existing use of land or structure	Agriculture
Proposed use of land or structure	Cattle Shed & Effluent Storage Tank.
Distance of proposed building line from edge of roadway	49.5m
Does the proposed development involve the provision of a piped water supply	N/A
Does the proposed development involve the provision of sanitary facilities	N/A

Planning & Development Act 2000 (as amended), regarding Exempted Development

Signature:

Sean Wallace

Date:

24/5/26





Note: This application must be accompanied by: -

- (a) €80 fee (**FOR PAYMENT, PLEASE CONTACT SEAN WALLACE AT 086 2492321**)
- (b) Site Location map to a scale of 1:2500 clearly identifying the location
- (c) Site Layout plan to the scale of 1:500 indicating exact location of proposed development
- (d) Detailed specification of development proposed



3.84 Slatted Tank 2.4 Deep

© Copyright. This drawing or design may not be reproduced without permission.



© Copyright: This drawing or design may not be reproduced without permission.

