

**ROSCOMMON COUNTY COUNCIL**  
**PLANNING AND DEVELOPMENT ACT, 2000 (as amended)**  
**SECTION 5 - DECLARATION ON DEVELOPMENT AND EXEMPTED DEVELOPMENT**  
**NOTIFICATION OF DETERMINATION**

**REGISTERED POST**

Gary Cunnane,  
Toberkeagh,  
Ballintubber,  
Co. Roscommon.

Reference Number: DED1011

Application Received: 10<sup>th</sup> March 2026

Name of Applicant: Gary Cunnane

Agent: Deane Associates, Old Church Road, Williamstown, Co. Galway.

WHEREAS a question has arisen as to whether the construction of a slatted tank to the rear of an existing slatted shed at Toberkeagh, Ballintubber, Co. Roscommon., is or is not development and is or is not exempted development.

AND WHEREAS Roscommon County Council, in considering this application, had regard particularly to:

- (a) Sections 2, 3, 4 and 5 of the Planning and Development Act, 2000, as amended.
- (b) Articles 6 and 9 of the Planning and Development Regulations, 2001, as amended.
- (c) Class 6A Part 3 Schedule 2 Article 6 of the Planning and Development Regulations 2001, as amended.
- (d) The record forwarded to Roscommon County Council in accordance with subsection (6)(c) of Section 5 of the Planning and Development Acts 2000 as amended.
- (e) The planning history of the site.

AND WHEREAS Roscommon County Council has concluded that:

- The works outlined above are development.
- The proposed development individually and in combination with other plans or projects would not be likely to have a significant effect on any European site and that the requirement for AA or EIAR does not apply with respect to the current case.
- The proposed development does not exceed the conditions and limitations attached to Class 6A Part 3 Schedule 2 Article 6 of the Planning and Development Regulations 2001, as amended, and is deemed an exempt development.

**NOW THEREFORE:**

By virtue of the powers vested in me by the Local Government Acts 1925 – 2024 and Section 5(2)(a) of the Planning and Development Act 2000 (as amended) and having considered the various submissions and reports in connection with the application described above, it is hereby declared that the said development for the **construction of a slatted tank to the rear of an existing slatted shed at Toberkeagh, Ballintubber, Co. Roscommon**, is development that is **exempted development** as defined within the Planning and Development Act 2000 (as amended) and associated Regulations.

Signed on behalf of the Council:



Mervyn Walsh,  
Administrative Officer,  
Planning.

Date: 4/10/2026

c.c. agent via email: Deane Associates  
[info@deaneassociates.ie](mailto:info@deaneassociates.ie)

**ADVICE NOTE**

Any person issued with a Declaration under Section 5 of the Planning and Development Act, 2000 (as amended) may, on payment to An Coimisiún Pleanála of the prescribed fee, refer a Declaration for review within 4 weeks of the date of the issuing of the Declaration.

**ADVICE NOTE**

This Declaration is based on the relevant Planning and Development Act 2000 (as amended) and the Planning and Development Regulations 2001 (as amended) at the date of issue. In the event that the Planning and Development Act 2000 (as amended) or the Planning and Development Regulations 2001 (as amended) change prior to the works being carried out this Declaration may no longer apply.

## Gemma Cunningham

---

**From:** Gemma Cunningham  
**Sent:** Friday 5 June 2026 10:04  
**To:** 'info@deaneassociates.ie'  
**Cc:** [REDACTED]  
**Subject:** Notification of Determination for DED1011

A Chara,

Please find attached correspondence for your attention regarding DED1011. Please be advise hard copy of the attached has been sent registered post to the applicant.

Kind Regards,

**Gemma Cunningham | Clerical Officer**

Áras an Chontae, Roscommon, Co. Roscommon. F42 VR98

☎ (090) 664 7420 ✉ [GCunningham@roscommoncoco.ie](mailto:GCunningham@roscommoncoco.ie)

🌐 [www.roscommoncoco.ie](http://www.roscommoncoco.ie)



Please note that I may be sending this email outside your working hours and I do not expect a response or action outside your own working hours

**Planner's Report on application under  
Section 5 of the Planning and Development Act 2000 (as amended)**

<b>Reference Number:</b>	DED 1011
<b>Re:</b>	Application for a Declaration under Section 5 of the Planning & Development Act, 2000, as amended, regarding Exempted Development as to whether the construction of a slatted tank to the rear of an existing slatted shed, is or is not development and is or is not exempted development.
<b>Name of Applicant:</b>	Gary Cunnane
<b>Location of Development:</b>	Toberkeagh, Ballintubber, Co. Roscommon.
<b>Site Visit:</b>	16 <sup>th</sup> April 2026

**WHEREAS a question has arisen as to whether the construction of a slatted tank to the rear of an existing slatted shed at the above address is or is not development and is or is not exempted development.**

I have considered this question, and I have had regard particularly to –

- (a) Sections 2, 3, 4 and 5 of the Planning and Development Act, 2000, as amended.
- (b) Articles 6 and 9 of the Planning and Development Regulations 2001, as amended.
- (c) Class 6A Part 3 Schedule 2 Article 6 of the Planning and Development Regulations 2001, as amended.
- (d) The record forwarded to Roscommon County Council in accordance with subsection (6)(c) of Section 5 of the Planning and Development Acts 2000 as amended.
- (e) The planning history of the site.

**Site Location & Development Description**

The subject site consists of an existing farmyard with existing agricultural structures namely an existing slatted shed, machinery shed and a dry bedded shed attached to slatted shed. The site is located behind a dwelling house and is accessed via farmyard access off the L1640 Local Primary Road. The subject site is situated c. km north of Ballintubber village. The proposed development consists of the construction of a slatted tank to the rear of an existing slatted shed.

**Archaeological and Cultural Heritage**

No RMP recorded in the likely zone of influence of the proposed development. No Protected structures or structures listed in the National Inventory of Architectural Heritage in the likely zone of influence of the proposed development.

## Appropriate Assessment



The closest European site to the proposed development is Corliskea/Trien/Cloonfelliv Bog SAC (Site Code 002110) located c. 3.6km from the subject site.

Having regard to the separation distance between the site and the closest Natura 2000 site and the nature of the proposal, there is no real likelihood of significant effects on the conservation objectives of these or other European sites arising from the proposed development. The need for further Appropriate Assessment can, therefore, be excluded.

## Planning History

### 4482A/76

**Development Description:** Erection of walls outside of house & entrance to farmyard.

**Applicant:** Mr. Liam Cunnane.

**Decision:** Granted.

### PD/05/348

**Development Description:** Permission to construct a slatted cattle shed together with all associated site works.

**Applicant:** Gary Cunnane.

**Decision:** Granted subject to 17 conditions.

## Relevant statutory provisions

### Planning and Development Acts 2000 (as amended)

Section 2. -(1)

“works” includes any act or operation of construction, excavation, demolition, extension, alteration, repair or renewal and, in relation to a protected structure or proposed protected structure, includes any act or operation involving the application or removal of plaster, paint, wallpaper, tiles or other material to or from the surfaces of the interior or exterior of a structure.

Section 3. –(1)

In this Act, “development” means, except where the context otherwise requires, the carrying out of any works on, in, over or under land or the making of any material change in the use of any structures or other land.

Section 4 (2) of the Planning and Development Act provides that the Minister, by regulations, provide for any class of development to be exempted development. The principal regulations made under this provision are the Planning and Development Regulations.

**Planning and Development Regulations, 2001 as amended**

Article 6 (1)

Subject to article 9, development of a class specified in column 1 of Part 3 of Schedule 2 shall be exempted development for the purposes of the Act, provided that such development complies with the conditions and limitations specified in column 2 of the said Part 3 opposite the mention of that class in the said column 1.

Article 9 (1)

Development to which article 6 relates shall not be exempted development for the purposes of the Act.

viiiB) comprise development in relation to which a planning authority or an Bord Pleanála is the competent authority in relation to appropriate assessment and the development would require an appropriate assessment because it would be likely to have a significant effect on the integrity of a European site.

Development Description	Conditions and Limitations
<p><b>CLASS 6A</b></p> <p>Works consisting of the provision of a structure for the storage of slurry, effluent or soiled water collected from agricultural buildings, agricultural farmyards and any ancillary provision to aid in the handling of the slurry, effluent or soiled water.</p>	<ol style="list-style-type: none"> <li>1. No such structure shall be used for any purpose other than the purpose of agriculture.</li> <li>2. The maximum storage capacity of any such storage facility shall not exceed 1000 cubic metres.</li> <li>3. The aggregate capacity of tanks, situated within the same farmyard complex, shall not exceed 1,500 cubic metres.</li> </ol>

4. The structure having regard to its size, use and location shall be constructed in accordance with Department of Agriculture, Food and the Marine and Department of Housing, Local Government and Heritage requirements and shall have regard to the need to avoid water pollution. The structure shall not be an earth lined Slurry/Effluent Store.
5. No such structure shall be situated, and no effluent from such structure shall be stored, within 10 metres of any public road.
6. No such structure within 100 metres of any public road shall exceed 8 metres in height.
7. No such structure shall be situated, and no effluent from such structure shall be stored, within 100 metres of any house (other than the house of the person providing the structure) or other residential building or school, hospital, church or building used for public assembly, save with the consent in writing of the owner and, as may be appropriate, the occupier or person in charge thereof.
8. No such structure shall be constructed within a flood zone identified in statutory land use plans as Flood Zone A or Flood Zone B or where the probability of flooding is moderate to high or erosion control zone.
9. No such structure shall be within 60 metres of a public or private water source.
10. No such structure shall be situated, at the closest point, less than 50 metres from a water course or water body in the case of new farmyards, and not less than 10m in the case of extensions/modifications to an existing facility.
11. All such tanks shall be constructed in accordance with the relevant specification published by the Department of Agriculture, Food and the Marine in force at the time of construction of the tank.

	<p>12. No unpainted metal sheeting shall be used for roofing or on the external finish of the structure.</p> <p>13. The use of this Class of exemption requires a declaration from the relevant Planning authority under section 5 of the Principal Act, declaring the exemption is applicable prior to commencement of construction.</p> <p>14. Ancillary provision shall include as appropriate the installation of any signage, fencing or other safety infrastructure as recommended by the Health and Safety Authority regarding Slurry Safety.</p>
--	--

**Environmental Considerations**

With regard to Article 9 (1)(a) of the Planning and Development Regulations 2001 (as amended), it is reasonable to conclude, on the basis of the information available, that the proposed development individually and in combination with other plans or projects would not be likely to have a significant effect on any European site and that the need for AA does not apply with respect to the current case.

I am satisfied that an Environmental Impact Statement or Appropriate Assessment are not required. It should be noted that any development for which Environmental Impact Assessment or Appropriate Assessment is required shall not be exempted development unless specifically exempted in regulations where there is provision in other legislation for the carrying out of EIA or AA. In addition, the restrictions on exemption Article 9 (1)(a) (viiB) exclude development which would otherwise be exempted development under these regulations where an AA is required.

**Assessment**

In accordance with the Planning and Development Act, 2000, as amended Section 3. (1) development is defined as the following: "In this Act, "development" means, except where the context otherwise requires, the carrying out of any works on, in, over or under land or the making of any material change in the use of any structures or other land". The proposed development is considered to be the carrying out of works. Works are defined in the Act as; "works" includes any act or operation of construction, excavation, demolition, extension, alteration, repair or renewal and, in relation to a protected structure....". It is considered that said works constitute development, as defined in Section 3 of the said Act.

## Extent of Works

- Construction of a slatted tank to the rear of an existing slatted shed.

With regard to the compliance with the conditions and limitations of Class 6A of Part 3 of Schedule 2 (Exempted development - Rural) the following assessment sets out how these apply to the current proposal:

### CLASS 6A

1. The proposed use for the structure is agriculture.
2. The proposed storage capacity of the proposed storage facility does not exceed 1000m<sup>3</sup> (157.96m<sup>3</sup>).
3. The aggregate of all tanks situated within the same farmyard complex does not exceed 1500m<sup>3</sup> (141.69m<sup>3</sup>).
4. The structure is in accordance with Department of Agriculture, Food and the Marine and the Department of Housing, Local Government and Heritage requirements and shall have regard to the need to avoid water pollution.
5. The proposed structure is situated more than 10 metres from a public road (98m).
6. The proposed structure is less than 8 metres in height.
7. The proposed structure is situated greater than 100m from a residential property.
8. The proposed structure is not situated in land use plans as Flood Zone A or Flood Zone B.
9. The proposed structure is greater than 60m from a public or private water source.
10. The proposed structure is greater than 50m from a water course or water body.
11. The proposed structure is in accordance with relevant specification published by the Department of Agriculture, Food and the Marine.
12. The proposed sheeting for the structure is pre-painted sheeting.
13. Yes
14. The responsibility lies with the applicant to include as appropriate the installation of any signage, fencing or other safety infrastructure as recommended by the Health and Safety Authority regarding Slurry Safety.

The applicant is proposing to construct a slatted tank for the storage of effluent on an existing farmyard. The proposed development has been assessed under Class 6A of Part 3 of Schedule 2 (Exempted development - Rural) and the proposal does not exceed the conditions and limitations attached to this class. Therefore, the proposed development is deemed an exempt development.

### **Recommendation**

**WHEREAS** a question has arisen as to whether the construction of a slatted tank to the rear of an existing slatted shed as outlined above at Toberkeagh, Ballintubber, Co. Roscommon, is or is not development and is or is not exempted development, I have considered this question, and I have had regard particularly to –

- (a) Sections 2, 3, 4 and 5 of the Planning and Development Act, 2000, as amended.
- (b) Articles 6 and 9 of the Planning and Development Regulations, 2001, as amended.

- (c) Class 6A Part 3 Schedule 2 Article 6 of the Planning and Development Regulations 2001, as amended.
- (d) The record forwarded to Roscommon County Council in accordance with subsection (6)(c) of Section 5 of the Planning and Development Acts 2000 as amended.
- (e) The planning history of the site.

**AND WHEREAS I have concluded that**

- The works outlined above are development.
- The proposed development individually and in combination with other plans or projects would not be likely to have a significant effect on any European site and that the requirement for AA or EIAR does not apply with respect to the current case.
- The proposed development does not exceed the conditions and limitations attached to Class 6A Part 3 Schedule 2 Article 6 of the Planning and Development Regulations 2001, as amended, and is deemed an exempt development.

**AND WHEREAS** I have concluded that the said development for the construction of a slatted tank to the rear of an existing slatted shed as outlined above at Toberkeagh, Ballintubber, Co. Roscommon, is exempted development. I recommend that a declaration to that effect should be issued to the applicant.

Signed:   
Graduate Planner

Date: 03/06/2026

  
Signed:  
Senior Executive Planner

Date: 03/06/2026











# MEMORANDUM

**To:** North Roscommon Area.

**From:** Mervyn Walsh, Administrative Officer, Planning Department.

**Date:** 19<sup>th</sup> March, 2026

**Re:** Application for a Declaration under Section 5 of the Planning & Development Act 2000 (as amended), regarding Exempted Development.

**Development:** WHEREAS a question has arisen as to whether the construction of a slatted tank to the rear of an existing slatted shed at Toberkeagh, Ballintubber, Co. Roscommon., is or is not development and is or is not exempted development.


**Applicant:** Gary Cunnane

**Planning Ref:** DED 1011

---

Attached, please find an application for a Declaration under Section 5 of the Planning & Development Act 2000 (as amended) regarding Exempted Development from Gary Cunnane for the said development above, which was received on 10<sup>th</sup> March, 2026.

Please let me have your recommendation.



---

**Mervyn Walsh,  
Administrative Officer,  
Planning Department.**

## Carmel Curley

---

**From:** Carmel Curley  
**Sent:** Thursday 19 March 2026 14:10  
**To:** info@deaneassociates.ie  
**Subject:** DED1011 - Gary Cunnane  
**Attachments:** DED 1011 - Ack Letter & Receipt.pdf

A Chara,

Please find enclosed Acknowledgement Letter & Receipt for the Section 5 Application submitted on behalf of Gary Cunnane – DED 1011.

Mise le meas,

Carmel

**Carmel Curley, Staff Officer,  
Planning Department, Roscommon County Council,  
Aras an Chontae, Roscommon, Co. Roscommon, F42 VR98**

☎: (090) 6637100

✉: [planning@roscommoncoco.ie](mailto:planning@roscommoncoco.ie) | 🌐 [www.roscommoncoco.ie](http://www.roscommoncoco.ie)

**MAP LOCATION**





Comhairle Contae  
Ros Comáin  
Roscommon  
County Council



Gary Cunnane,  
Toberkeagh,  
Ballintubber,  
Co. Roscommon.

Date: 19<sup>th</sup> March, 2026  
Planning Reference: DED 1011

Re: Application for a Declaration under Section 5 of the Planning & Development Act 2000 (as amended), regarding Exempted Development.

Development: WHEREAS a question has arisen as to whether the construction of a slatted tank to the rear of an existing slatted shed at Toberkeagh, Ballintubber, Co. Roscommon., is or is not development and is or is not exempted development.

\*\*\*\*\*

A Chara,

I wish to acknowledge receipt of your application which was received on the 10<sup>th</sup> March, 2026, for a Declaration under Section 5 of the Planning & Development Act 2000 (as amended), regarding Exempted Development along with the appropriate fee in the sum of €80.00, Receipt No. L01/0/239759 dated 18<sup>th</sup> March, 2026, receipt enclosed herewith.

**Note:** Please note your Planning Reference No. is **DED 1011**.  
This should be quoted in all correspondence and telephone queries.

Mise le meas,

Mervyn Walsh,  
Administrative Officer,  
Planning Department.

c.c. agent via email: Deane Associates  
[info@deaneassociates.ie](mailto:info@deaneassociates.ie)

Roscommon County Council  
Aras an Chontae  
Roscommon  
09066 37100  
\*\*\*\*\*

18/03/2026 11:10:30

Receipt No : L01/0/239759

GARY CUNNANE  
C/O DEANE ASSOCIATES  
OLD CHURCH ROAD  
WILLIAMSTOWN  
CO. ROSCOMMON

PLANNING APPLICATION FEES	80.00
GOODS	80.00
VAT Exempt/Non-vatable	
DED 1011	

Total : 80.00 EUR

Tendered  
Cheque 80.00  
000629

Change : 0.00

Issued By : Aine McDermott  
From : Central Cash Office



Conhairle Contae  
Ros Comáin  
Roscommon  
County Council



Áras an Chontae,  
Roscommon,  
Co. Roscommon.

Phone: (090) 6637100

Email: [planning@roscommoncoco.ie](mailto:planning@roscommoncoco.ie)

## Roscommon County Council

### Application for a Declaration under Section 5 of the

### Planning & Development Act 2000 (as amended), regarding Exempted Development

Name of Applicant(s)	GARY LUNNANE TOBERKEAGH BALLINTOBER CO. ROSCOMMON
Name of Agent	DEANE ASSOCIATES OLD CHURCH ROAD WILLIAMSTOWN CO. GALWAY
Nature of Proposed Works	CONSTRUCT SLATTED TANK TO THE REAR OF EXISTING SLATTED SHED.
Location & Address of Subject Property to include, Eircode (where applicable), Townland & O.S No.	TOBERKEAGH BALLINTOBER CO. ROSCOMMON
Floor Area: a) Existing Structure b) Proposed Structure	a) <u>240 sq. mt.</u> b) <u>70 sq. mt.</u>
Height above ground level:	0.2m
Total area of private open space remaining after completion of this development	N/A
Roofing Material (Slates, Tiles, other) (Specify)	PRECAST CONCRETE SLATS

## Roscommon County Council

### Application for a Declaration under Section 5 of the

Proposed external walling (plaster, stonework, brick or other finish, giving colour)	N/A
Is proposed works located at front/rear/side of existing house.	REAR OF EXISTING SHEDS
Has an application been made previously for this site	YES — 05/348
If yes give ref. number (include full details of existing extension, if any)	05/348
Existing use of land or structure	AGRICULTURAL LANDS
Proposed use of land or structure	STORAGE OF SLURRY
Distance of proposed building line from edge of roadway	98m
Does the proposed development involve the provision of a piped water supply	NO
Does the proposed development involve the provision of sanitary facilities	NO


### Planning & Development Act 2000 (as amended), regarding Exempted Development

Signature:



Date:

03/03/2026



**Note:** This application must be accompanied by: -

- ✓(a) €80 fee
- ✓(b) Site Location map to a scale of 1:2500 clearly identifying the location
- ✓(c) Site Layout plan to the scale of 1:500 indicating exact location of proposed development
- ✓(d) Detailed specification of development proposed

# Land Registry Compliant Map




Tailte Éireann

OS LICENCE No.: AR 0039126

**SITE OUTLINED IN RED**

**APPLICANT OWNS /HAS CONTROL OF LAND OUTLINED IN BLUE**



**CENTRE COORDINATES:**  
ITM 572010,776426

**PUBLISHED:** 06/03/2026  
**ORDER NO.:** 50522461\_1

**MAP SERIES:** 1:5,000  
**MAP SHEETS:** 2284, 2285

**COMPILED AND PUBLISHED BY:**  
Tailte Éireann,  
Phoenix Park,  
Dublin 8,  
Ireland.  
D08F6E4

[www.tailte.ie](http://www.tailte.ie)

Any unauthorised reproduction infringes Tailte Éireann copyright.


No part of this publication may be copied, reproduced or transmitted in any form or by any means without the prior written permission of the copyright owner.

The representation on this map of a road, track or footpath is not evidence of the existence of a right of way.

This topographic map does not show legal property boundaries, nor does it show ownership of physical features.

©Tailte Éireann, 2026.  
All rights reserved.

**SITE LOCATION MAP**  
SCALE 1 : 2500



**OUTPUT SCALE: 1:2,500**

**CAPTURE RESOLUTION:**  
The map objects are only accurate to the resolution at which they were captured. Output scale is not indicative of data capture scale. Further information is available at: [www.tailte.ie](http://www.tailte.ie); search 'Capture Resolution'

**LEGEND:**  
To view the legend visit [www.tailte.ie](http://www.tailte.ie) and search for 'Large Scale Legend'



571718  
778641  
7786211  
571718

57201  
778641  
572011  
572301

# Land Registry Compliant Map




Tailte  
Éireann

OS LICENCE No.: AR 0039126

**SITE OUTLINED IN RED**

**APPLICANT OWNS /HAS CONTROL OF LAND OUTLINED IN BLUE**



**CENTRE COORDINATES:**  
ITM 572010,776426

**PUBLISHED:** 06/03/2026  
**ORDER NO.:** 50522461\_1

**MAP SERIES:** 1:5,000  
**MAP SHEETS:** 2284, 2285

**COMPILED AND PUBLISHED BY:**  
Tailte Éireann,  
Phoenix Park,  
Dublin 8,  
Ireland.  
D08F6E4

[www.tailte.ie](http://www.tailte.ie)

Any unauthorised reproduction infringes Tailte Éireann copyright.


No part of this publication may be copied, reproduced or transmitted in any form or by any means without the prior written permission of the copyright owner.

The representation on this map of a road, track or footpath is not evidence of the existence of a right of way.

This topographic map does not show legal property boundaries, nor does it show ownership of physical features.

©Tailte Éireann, 2026.  
All rights reserved.

**SITE LOCATION MAP**  
SCALE 1 : 2500



**OUTPUT SCALE: 1:2,500**

**CAPTURE RESOLUTION:**  
The map objects are only accurate to the resolution at which they were captured. Output scale is not indicative of data capture scale. Further information is available at: [www.tailte.ie](http://www.tailte.ie); search 'Capture Resolution'

**LEGEND:**  
To view the legend visit [www.tailte.ie](http://www.tailte.ie) and search for 'Large Scale Legend'



o u g h  
o u g h

05/348 Planning Boundary

Applicants Uncle's dwelling house  
(Letter of consent in place)

Applicants dwelling house

Applicants parents dwelling house  
(Letter of consent in place)

Existing Machinery sheds

Existing Dry bed shed shaded orange - Area 95sq mt

Existing Slatted shed hatched green  
Granted under planning ref 05/348

PROPOSED SLATTED TANK


DRAWINGS ARE FOR PLANNING PURPOSES ONLY

AREA OF SITE: 0.470 Hectares

SITE OUTLINED IN RED

0.80

SITE LAYOUT  
SCALE 1 : 500



GENERAL NOTES:

- G1 THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT ARCHITECTS AND ENGINEERS DRAWINGS.
- G2 ANY QUERIES OR DISCREPANCIES ARE TO BE REFERRED TO THE ARCHITECT/ENGINEER IMMEDIATELY.
- G3 FIGURED DIMENSIONS ONLY TO BE USED.
- G4 ALL DIMENSIONS IN MILLIMETRES UNLESS NOTED OTHERWISE.

Rev No.	Date	Revision Note	By	Chk

Old Church Road, Willestown, Co. Galway  
Email: info@deaneassociates.ie  
Web: www.deaneassoc.ie  
Tel: 094 9611079

Client: GARY CUNNANE  
Project: PROPOSED SLATTED TANK AT TOBERKEAGH, BALLINTOBER

Drawing Title: SITE LAYOUT			
By: RK	Ckd: DD	Scale: 1:500 @ A3	Date: FEB 2025
Project: GC226	Dwg No: 201	Rev: PO	

o u g h  
o u g h

05/348 Planning Boundary

Applicants Uncle's dwelling house  
(Letter of consent in place)

Applicants dwelling house

Applicants parents dwelling house  
(Letter of consent in place)

0.80

DRAWINGS ARE FOR PLANNING PURPOSES ONLY

AREA OF SITE: 0.470 Hectares

SITE OUTLINED IN RED



Existing Machinery sheds

Existing Dry bed shed shaded orange - Area 95sq mt

Existing Slatted shed hatched green  
Granted under planning ref 05/348

PROPOSED SLATTED TANK

SITE LAYOUT  
SCALE 1 : 500



GENERAL NOTES:


- G1 THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT ARCHITECTS AND ENGINEERS DRAWINGS.
- G2 ANY QUERIES OR DISCREPANCIES ARE TO BE REFERRED TO THE ARCHITECT/ENGINEER IMMEDIATELY.
- G3 FIGURED DIMENSIONS ONLY TO BE USED
- G4 ALL DIMENSIONS IN MILLIMETRES UNLESS NOTED OTHERWISE.

Rev No.	Date	Revision Note	By	Chk




Client: GARY CUNNANE  
Project: PROPOSED SLATTED TANK AT TOBERKEAGH, BALLINTOBER




Drawing Title: SITE LAYOUT	By: RK	Chk: DD	Scale: 1:500 @ A3	Date: FEB 2023
Project: GC226	Dwg No: 201	Rev: PO		



SLURRY STORAGE TANK SECTION  
SCALE 1 : 100



SLURRY STORAGE TANK PLAN  
SCALE 1 : 100



Old Church Road, Wexford, Co. Galway  
Email: info@deaneassociates.ie  
Web: www.deaneassociates.ie  
Tel: 094 9643079

Client: GARY CUNNANE

Drawing Title: TANK PLANS AND SECTION

Project: PROPOSED SLATTED TANK AT TOBERKEAGH,  
BALLINTOBER

By: RK

Ckd: DD


Scale: 1:100 @ A3

Date: FEB 2026


Project: GC226

Dwg No: 101

Rev: P0



SLURRY STORAGE TANK SECTION  
SCALE 1 : 100



SLURRY STORAGE TANK PLAN  
SCALE 1 : 100

